

**RFQ 19GT5020Q0087 – QUESTIONS AND ANSWERS
CONTAINERS FOR CHECKPOINTS**

Please refer to the RFQ where you will find all the technical information described for the quotation of these containers.

1. Will transportation be a variable cost for each Area? Because of the distance, there will be a differential, so please tell us how to present it in the offer.

As indicated in the RFQ, the delivery will be to different sites and on different dates. Hence, four deliveries will need to be coordinated. Offerors must quote according to the distance of each site. The offer must be detailed as requested in the table below.

II. Delivery Location and Time

A. Contractor shall deliver the assembled containers to the US Embassy in Guatemala per the detailed scheduled below:

1. Chisec, Alta Verapaz. Delivery date September 28, 2020
2. Poptun, Peten. Delivery date October 28, 2020
3. Taxisco, Santa Rosa, Delivery date November 15, 2020
4. Tecpan, Chimaltenango, Delivery date December 1, 2020

B. The Contractor shall be able to deliver within a four months period. Dates are estimated and could shift a little bit. Exact locations will be advised before delivery.

#	Description	Qty.	Unit Price	Per	Total
1	Checkpoint containers - Chisec, Alta Verapaz	2	Q	EA	Q
2	Checkpoint containers - Poptun, Peten	2	Q	EA	Q
3	Checkpoint containers - Taxisco, Santa Rosa	2	Q	EA	Q
4	Checkpoint containers - Tecpan, Chimaltenango	2	Q	EA	Q
*		12% VAT		Q	
*		GRAND TOTAL		Q	

2. We do not have information on the land. If more work is required, will we have to handle an extra for these works that can be assessed from the first visit? Or can we leave it only mentioned in text, to quantify it on the first visit?

As mentioned on page 5 of the RFQ, Offerors must consider all costs and include them in the proposal. The Contractor that receives the award will be given the dates and installation addresses. They will be able to make a visit prior to the delivery of the containers. However, any costs that they were not included cannot be added to the initial proposal.

- B. The prices listed below shall include all labor, materials, transportation, all necessary permits, delivery charges for material and/or equipment needed any other customary charges and tasks not considered in this proposal.

3. Is the time to implement in the 4 places the same?

No, there are estimated dates for delivery to each location. Nonetheless, they may vary a little.

II. Delivery Location and Time

A. Contractor shall deliver the assembled containers to the US Embassy in Guatemala per the detailed schedule below:

1. Chisec, Alta Verapaz. Delivery date September 28, 2020
2. Poptun, Peten. Delivery date October 28, 2020
3. Taxisco, Santa Rosa, Delivery date November 15, 2020
4. Tecpan, Chimaltenango, Delivery date December 1, 2020

B. The Contractor shall be able to deliver within a four-month period. Dates are estimated and could shift a little bit. Exact locations will be advised before delivery.

4. Are secondary urbanization and infrastructure services part of the offer?

Urbanization and infrastructure services are not being requested in this solicitation.

5. Do you develop the bases of the containers or does it have to be included as civil works?

As stated in the description of the Statement of Work for this solicitation, the bases of the containers must be included in the price of the proposal. All items considered necessary, to install the containers installed must be included in the proposal.

Description:

40-foot sea containers modified to be used as office space placed on top of 12" concrete blocks, piles metal blocks or rims.

A minimum of six footing perfectly leveled placed under two containers. Rims size 16 or larger, or split or cast in-situ concrete pedestals may be used. Pedestals must be of not less than 0.25 x 0.25 m in section, minimum vertical # 3 grade 40 and horizontal # 2 grade 40 0.20 m above ground level. Must be attached together in all meeting points, utilizing ISO twist locks. Each container must comply with:

6.- Gardening of the complex, as well as the enclosures must be included?

No, gardening is not requested. These are Checkpoints that will be installed on the sides of the road in each location.

7.- Who provides the oxygen, nitrogen, compressed air connections? Are the facilities you require part of the offer?

The Offeror must include in the proposal the cost of all the equipment that they consider will be needed for the preparation and delivery of the containers.

- B. The prices listed below shall include all labor, materials, transportation, all necessary permits, delivery charges for material and/or equipment needed any other customary charges and tasks not considered in this proposal.

8.- If potable water is provided for connection to the system or the plant must be included water treatment plant?

Drinking Water connections are not being requested for this solicitation, nor any treatment plant.

9.-Is the treatment plant part of the package?

Treatment plants are not being requested for the containers.

10.- Where should we consider the electrical power connection point, drainage, drinking water, gas, oxygen, etc.... distances to the connection point?

Please review the RFQ and drawings included. The container will carry a 75KV Generator and the installation will be provided by the generators supplier.

11.- Start-up time, to whom are the facilities delivered?

Awarded Contractor will receive specific details on whom and where to reach out to for Containers delivery and installation for the specified dates and location.

12.-Should training time be considered?

This solicitation does not include training requirements.

13. Custom graphic adaptation to containers is required? Logos, flags, paint color, etc ...

Please refer to page 5 of the published solicitation for the specific requirements for the containers regarding paint.

14. What kind of equipment is required for the containers, beds, area of operation and surgery, intensive, recovery, covid, etc. Which one specifically for each of the locations.

Please note these containers will be used as office space.

15. Is the installation area accessible for trucks?

Yes, areas in each location are open roads.

16. Is there space with a tire crane for maneuvering?

Yes, there is space for a tire crane. Consider that an awning will be placed before the containers, as described in the solicitation drawings.

17.-The area is delivered in what conditions?

Area for the containers is road side. Contractor needs to consider the preparation of the area for the bases set up as requested in the RFQ.

18.-Is there a design of the complex?

Designs area included in the solicitation. Take note that only the containers with all the specific requirements indicated there in are being requested.

19.- Do you have to include exterior lighting?

Please note there is no exterior lightning specified in this solicitation.

20.-Is there a technical visit to the locations?

There will not be a site visit for this solicitation. The awarded vendor will have access to the addresses so that they can check the locations before installing the containers.